



322/390/54/2016

Gdańsk, 08-02-2016

HYGIENIC CERTIFICATE No 52/322/54/2016

- 1. Name of product (material)** Varnished MDF/HDF
thickness ranges: 1,0 - 5,0 mm
- 2. Application** furniture production and interior's decorate
- 3. Applicant institution** Pfleiderer MDF Sp. z o.o.
ul. Wiórowa 1
PL-19-203 Grajewo
- 4. Manufacturer** Pfleiderer MDF Sp. z o.o.
ul. Wiórowa 1
PL-19-203 Grajewo
- 5. The product meets the hygienic requirements provided that the following conditions are met:**
 - The load with the material amounts to $1,9 \text{ m}^2/\text{m}^3$ in relation to the cubage of residential premises intended for permanent stay of patients in health service buildings, children and young people in school buildings, and of premises intended for storing food products, i.e. premises class /
 - The load with the material amounts to $3,8 \text{ m}^2/\text{m}^3$ in relation to the cubage of rooms in public buildings other than those mentioned above and in utility room in residential premises i.e. premises class B according with the ordinance by the Minister of Health and Social Care of March 12, 1996 M.P. 1996 No.19 pos.231.The certificate does not concern working conditions and occupational hygiene during the assembly of product. Facilities that use the product should be ventilated until the odor disappears.
- 6. Basis of certificate:** applications of OB-RPPD Sp. z o.o. BW/452/101/16 of January 27, 2016 Certificate of Examination No 5714/116/2016 of February 6, 2016 issued by Research & Development Centre for Wood – Based Panels in Czarna Woda.
Hygienic class E1.
- 7. The present certificate may be changed or voided if either party presents sufficient evidence. The document becomes invalid after 5 years since the date of issue or if any changes either in composition or manufacturing technology of the product have been introduced.**

BEROMSK
Zakład Toksykologii Środowiska
Andrzej Wólczyński
prof. dr hab. Lekt. Włocza